

Data Sheet

Transformer Terminal Block

Pitch: 7,50 mm

Serie: A36006

Customer Information for special Item

EDCON Customer : 0

Customer Version No. : 0

EDCON-COMPONENTS



Technical Discription


Electrical	cULus	IEC
Rated Voltage	300 Volt	750V
Rated Current	20A	41A
Withstanding Voltage	3,0KV	3,0KV
Wire Range		
Solid Wire	4mm ²	
Stranged Wire	4mm ²	
Insulation Resistance	5000MΩ / 1000V	

Mechanical	
Operating Temperature	-40°C ~ +115°C
Wire Strip Length	10~12mm

Dimensions	
Pitch (mm)	7,50
Poles	1 + 2Pos.

Materials	
1 Terminal Housing	PA66 UL94V-0
2 Cage	Brass Ni, plated
3 Contact	Copper Tin plated
4 Terminal screw	M4 Steel Cr ³⁺ Zn plated
5	

Drawing (Dimension in mm)



Transformer Terminal Block

Part No.: **A36006**

Customer:

DRW:	Jason	CHKD	Wilson	MATL:	Wilson	TOLERANCE	Mason	DATE	15.10.2015
APPD:	Schumi			FINISH	Jamy		Sheet No.		1 from 4


EDCON-COMPONENTS




Ordering Informations

Serie	No. of Pos.	Body Color	No Function	Approval Code	ROHS	Packing	EDCON Cust. No.	Customer Version		
-------	-------------	------------	-------------	---------------	------	---------	-----------------	------------------	--	--

A36006	03	OR	A	N	R	B				
---------------	-----------	-----------	----------	----------	----------	----------	--	--	--	--

Pitch 7,50	03= Number of Pos.		A= Slotted Screw Type (Standard) 	N= NON Approval A= UL /UR Approval Please consult EDCON for available	R= ROHS Conform N= NON ROHS Conform	B= Bulk-Ware I= Individual Package	xxxxxx= Customer Number	xxx= Customer Version ??(Printing)		
---------------	---------------------------	--	--	--	--	---	--------------------------------	---	--	--

			B= Cross Slotted Screw Type 	B= VDE Approval Please consult EDCON for available					
	GY= Gray								
	OR= Orange			C= TÜV Approval Please consult EDCON for available					
				0= NON Plastic Approval	1= UL for Plastic Approval				

Transformer Terminal Block

Part No.: **A36006**


DRW:	Jason	CHKD	Wilson	MATL:	Wilson	TOLERANCE	Mason	DATE	15.10.2015
APPD:	Schumi			FINISH	Jamy		Sheet No.		3 from 4

Customer:



Soldering Profile Curve

Classification Reflow Profile (JEDEC J-STD-020C)



Transformer Terminal Block	
Part No.:	A36006
Customer:	

DRW:	Jason	CHKD:	Wilson	MATL:	Wilson	TOLERANCE:	Mason	DATE:	15.10.2015
APPD:	Schumi			FINISH:	Jamy		Sheet No.	4 from 4	